

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION
TENTATIVE ORDER R5-2019-XXXX
RESCINDING WASTE DISCHARGE REQUIREMENTS ORDER
R5-2003-0143

The California Regional Water Quality Control Board, Central Valley Region (Central Valley Water Board), finds that the Central Valley Water Board adopted the following Order which is no longer applicable for the reasons shown:

Waste Discharge Requirements Order R5-2003-0143, adopted on 5 September 2003, and prescribes requirements for the discharge from Butte Community College Campus, Butte County (Facility). The Facility is comprised of a wastewater collection system, influent pump station with bar screen, package aerated digester with extended aeration, secondary clarifier and aerobic digester, two (2) stabilization ponds, two (2) primary disposal ponds; or if needed, several shallow marsh disposal ponds. The Facility is now regulated under Water Quality Order 2014-0153-DWQ (General Order) for discharges to land from small domestic systems with a maximum average daily flow of 100,000 gallons or less. Therefore, it is appropriate to rescind Waste Discharge Requirements Order R5-2003-0143.

IT IS HEREBY ORDERED that the above Waste Discharge Requirements Order R5-2003-0143 is rescinded.

I, Patrick Pulupa, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the Central Valley Water Board on
<DD MONTH> 2019

PATRICK PULUPA, Executive Officer